

民用机场专用设备  
**审定合格证**  
AIRPORT EQUIPMENT CERTIFICATE

证书编号/Certificate No.: 08404934

有效期至/Expiration Date: 2016-11-10

根据《民用机场管理条例》(中华人民共和国国务院令 533 号)规定,下列产品通过合格性审定,可以在民用机场内使用:

This certificate is issued in accordance with the P.R.CHINA State Council Order No.533, *The Regulation on Airport Management*, and certifies that the following equipment has passed the qualification examination for use in airport:

**隔离变压器**  
**Isolation Transformer**

型号/Model: GL-100


制造商/Manufacturer

上海航安机场设备有限公司  
Airsafe Airport Equipment Co., Ltd.

地址/Address

上海市嘉定区徐行镇安新路 38 号  
No.38 Anxin Road, Xuhang Town, Jiading District, Shanghai

设备外观&主要性能指标/ Basic Information



额定功率 Power Rating	100W
额定电流 Current Rating	6.6/6.6A
频率 Frequency	50/60Hz
外封材料 Encapsulation Material	合成橡胶 Synthetic Rubber

备注 Notes:


- 设备详细外观及性能指标作为本证书的一部分打印于本证书背面  
Appearance and specifications of the equipment are printed overleaf as part of this certificate
- 下列方框内的登记记录表示本证书所示内容发生了变更,变更具体内容打印于本证书背面  
Records sealed below on the blanks indicate revisions of this certificate with explanations printed overleaf

--	--	--	--	--

颁发日期:  
Issue Date:

2011-01-10





最大初级电压  
Max. Circuit Voltage 5000V

最大次级开路电压  
Max. Secondary Circuit Voltage 70V

最小功率因数  
Mix. Power Factor 0.95

效率  
Efficiency  $\geq 85\%$